



ADDENDUM - 01

Title: **Replacement of Arena Dasher Boards System, Glass, and Safety Netting**

Reference: LRD 2026-01

Addendum Date: Thursday, February 18, 2026

Closing Date: **Friday, March 6, 2026**

Closing Time: **1:05 pm**

Location: Lucknow & District Recreation Department
662 Campbell Street
Lucknow, ON, N0G 2H0
Attention: **Steve Bushell, Facility Manager**
Email: lucrec@hurontel.on.ca
Phone: 519-528-3008 ext. 1#

The following changes shall replace and/or be incorporated into and form part of the Tender Documents.

1. Arena Panels

1.1 A panelized arena dasher board system shall consist of prefabricated, modular panel sections having aluminum framing and high-density polyethylene (HDPE) facing with colour matched fasteners. A 5" frame deep profile is required throughout the entire system. The design of all panels whether straight, curved, or in which a gate is located shall be similar. Each Panel shall be 48" in height from the refrigerated floor and no more than 8' in length. The arena panels shall include all gates, hardware, shielding supports, and anchor bolts required to provide a complete and functional dasher board system are required, with extra items as listed in the specification checklist. Due to the current dasher board support posts also supporting the spectator seating and lobby wall, current steel posts may be re-used for these areas.

- If removing the current steel posts, the vendor shall be responsible for ensuring the previously supported spectator seating and lobby wall are adequately supported during removal and installation of the dasher boards, and shall likewise provide an adequate solution for supporting the areas after the dasher boards are installed.
- If re-using the current steel posts, all other products shall be replaced to match the prefabricated, modular panel sections as closely as possible.

1.10 3/8" thick white HDPE backing and gap filling shall be installed as specified at site meeting. This shall include three of the four corners at full height, as well as player and penalty boxes at half height (to accommodate water bottle shelves), and along the spectator seating. Backer Panels shall be securely attached to the dasher board framing.

3. Spectator Shielding

3.3. 5/8" thick clear tempered glass shall be installed on the corners and ends of the rink, at a height of 72" above the cap rail.

5. Gates/Doors

5.2. Supply and install one (1) double door maintenance gates in the same location as current

1. Maintenance door shall have HDPE thresholds.
2. Gates shall be two 48" doors for a total of 96"

- 3. Thresholds shall be angled on edge away from ice surface to allow for easier transition of pedestrian traffic during off season activities.
- 5.5. Supply and install one (1) 48" single door hockey net gate in the same locations as the current 36" hockey net gate.
- 1. Hockey Net gate to include castors
- 5.11. Supply and install one (1) 7' Single door maintenance gates in the same location as current 8' removable section.
- 1. Maintenance door shall have HDPE thresholds.
 - 2. Maintenance door shall have castors
 - 3. Thresholds shall be angled on edge away from ice surface to allow for easier transition of pedestrian traffic during off season activities.
 - 4. Maintenance door to include castors, slide bar gate latch or equivalent and cane bolts rather than the latch requirements listed in 5.10

Specifications Compliance Checklist

Specification Compliance Checklist	Yes/No
Dasher Boards System (prefabricated, modular panel sections with aluminum framing HDPE facing with colour matched fasteners).	
Dasher Board Height (48").	
Ad Panels (30x 3/8 White HDPE Backing with 1/8 Polycarbonate covering).	
8" Coloured Kick Plate.	
Coloured Cap Rail.	
Additional coloured fasteners (min. 500 white and 100 of each additional colour)	
Anchor System (5/8" diameter Hilti adhesive anchors or equivalent for permanent installation).	
Player, Penalty, and Time Keeper Box Sizing.	
Player and Penalty Box Benches.	
Player, Penalty, and Time Keeper Flooring	
End & Corner Glass (6' Supported).	
Player side glass including Penalty and Time Keeper Boxes (6' Supported).	
Spectator Side Glass (6' Seamless).	

Each piece of glass shall bear an approval stamp from a certified testing facility.	
Glass Supports (Supported).	
Glass Supports (Seamless).	
(2) 12' Double Door Equipment Gates.	
(1) 8' Double Door Maintenance Gates.	
(1) 7' Single Door Maintenance Gate	
(1) 4' Single Door Hockey Goal Gate.	
(2) 3' Single Door Entrance Gate.	
(11) 30" Single Door Gates.	
Gate Thresholds shall be white (HDPE).	
All double door gates to include castors, slide bar gate latch and cane bolts.	
All single door gates shall be single latch type equipped with a flush mounted push-button latch release in the cap rail on the ice side.	
Protective netting shall be a clear monofilament netting.	
All gate hinges and latched shall be Stainless Steel.	
Unless otherwise noted, all nuts, washers, and bolts shall be zinc plated as minimum.	
All measurements to ensure proper fit and installation shall be the responsibility of the Proponent.	
Minimum 12-month warranty.	
Completion of project by July 10 2026.	

February 18 2026

Proponent's Name (Print)

Proponent's Signature

Date

(Bidders shall sign and date all addenda and attached copies to the submitted Tender)